

CSULB Drinking Water Station Lead Test Results - Pre-1990 Buildings

| Test ID # | Bldg | Drinking Fountain Location | Date of Testing | Test Result | Notes | Test Technician |
|-----------|------|----------------------------|-----------------|---------------------|------------------|------------------------------|
| 1 | ECS | 2nd FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 2 | ECS | 3rd FL | 1/17/2018 | 5.91 ppb | | Titan Environmental Services |
| 3 | ECS | 4th FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 4 | ECS | 5th FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 5 | ECS | 6th FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 6 | VEC | 1st FL W | 12/21/2017 | | Inactive Station | |
| 7 | VEC | 2nd FL N | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 8 | VEC | 2nd FL S | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 9 | VEC | 3rd FL N | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 10 | VEC | 3rd FL S | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 11 | VEC | 4th FL N | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 12 | VEC | 4th FL S | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |

| | | | | | | |
|----|--------|--------------------|------------|---------------------|--|--------------------------------|
| 13 | VEC | 5th FL N | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 14 | VEC | 5th FL S | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 15 | EN2 | 2nd FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 16 | EN2 | 3rd FL | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 17 | ET | 1st FL W | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 18 | ET | 2nd FL E #1 | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 19 | ET | 2nd FL E #2 | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 20 | ET | Exterior West Side | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 21 | ET | Machine Shop | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 22 | HSD | 1st FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 23 | HSD | 1st FL N | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 24 | Design | 1st FL @ 131 | 1/11/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 25 | SSPA | 1st FL S of Elev | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 26 | SSPA | 1st FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |

| | | | | | | |
|----|------|-----------------|------------|---------------------|------------------|------------------------------|
| 27 | SSPA | LL FL #1 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 28 | SSPA | LL FL #2 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 29 | SSPA | 2nd FL N | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 30 | SSPA | 2nd FL S | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 31 | SSPA | 2nd FL W | 1/17/2018 | Not Detected | | Titan Environmental Services |
| 32 | SSPA | 3rd FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 33 | MIC | 1st FL Exterior | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 34 | MIC | 2nd FL Exterior | | | Inactive Station | |
| 35 | MIC | 3rd FL Exterior | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 36 | PH1 | 1st FL E | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 37 | PH1 | 1st FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 38 | PH1 | 2nd FL E | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 39 | PH1 | 2nd FL Center | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 40 | PH1 | 2nd FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 41 | FA4 | 1st FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |

| | | | | | | |
|----|-----|------------------|------------|------------------------|------------------|-------------------------------|
| 42 | FA4 | 2nd FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 43 | FA4 | 2nd FL E | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 44 | FA4 | 3rd FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 45 | FA3 | Exterior N | | | Inactive Station | |
| 46 | FA2 | 2nd FL E | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 47 | FA2 | 2nd FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 48 | FA1 | 2nd FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 49 | UTC | 1st FL N | 1/17/2018 | 127 ppb | | Ttitan Environmental Services |
| 50 | UTC | 1st FL S | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 51 | UTC | 2nd FL W | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 52 | TA | 1st FL NE | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 53 | TA | 1st FL Room 128 | 1/17/2018 | 20.8 ppb | | Ttitan Environmental Services |
| 54 | TA | 1st FL S Hallway | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 55 | TA | 2nd FL S Hallway | 1/17/2018 | Not Detected (< 5 ppb) | | Stericycle- Andres Quinones |
| 56 | TA | 2nd FL Rm 241 | 1/17/2018 | Not Detected (< 5ppb) | | Ttitan Environmental Services |

| | | | | | | |
|----|----------|--------------------|------------|-------------------------|------------------|------------------------------|
| 57 | TA | LL Hallway #1 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 58 | TA | LL Hallway #2 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 59 | LAB | 2nd FL | 1/17/2018 | Not Detected (<5 5 ppb) | | Titan Environmental Services |
| 60 | LAB | 3rd FL | 12/29/2017 | Positive (>15 ppb) | | Stericycle- Jorge Gonzalez |
| 61 | SHS | 1st FL Hallway | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 62 | SHS | 2nd FL Rm 218 | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 63 | SHS | 2nd FL Rm 260 | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 64 | Old Nurs | Exterior Rm 10 | 1/11/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 65 | ED2 | 1st FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 67 | ED2 | 2nd FL W | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 68 | ED2 | 2nd FL | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 69 | EED | 1st FL NW | 12/29/2017 | Negative (< 15 ppb) | | Jorge Gonzalez |
| 70 | EED | 1st FL N | 12/29/2017 | Negative (< 15 ppb) | | Jorge Gonzalez |
| 71 | LIB | 1st FL Emp Hallway | | | Inactive Station | |
| 72 | PSY | 1st FL W Rm 204 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 73 | PSY | 2nd FL E RM 226 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |

| | | | | | | |
|----|-----|----------------------|------------|------------------------|------------------|------------------------------|
| 74 | PSY | 3rd FL E Rm 338 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 75 | PSY | 3rd FL W Rm 308 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 76 | PSY | 4th FL E Rm 436 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 77 | FCS | LL by Elevator | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 78 | FCS | 1st FL N Rm 127 | 12/29/2017 | Negative (< 15 ppb) | | Stericycle- Jorge Gonzalez |
| 79 | BH | 1st FL E by Elevator | 12/21/2017 | | Inactive Station | |
| 80 | BH | 1st FL N Hallway | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 81 | BH | 2nd FL by Rm 250 | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 82 | BH | 2nd FL by Rm 289 | 1/17/2018 | Not Detected (< 5 ppb) | | Titan Environmental Services |
| 83 | BH | 3rd FL E by Rm 344 | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 84 | BH | 3rd FL E by Rm 300 | 12/21/2017 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 85 | KIN | Hallway by Rm 84 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 86 | KIN | Hallway by Rm 61 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 87 | KIN | Hallway by Rm 53 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 88 | KIN | West Gym S End | 1/17/2018 | Not Detected (<5 ppb) | | Titan Environmental Services |

| | | | | | | |
|-----|-------|-------------------------|----------|---------------------|------------------|-----------------------------|
| 89 | KIN | West Gym N End | 1/4/2018 | | Inactive Station | Stericycle- Andres Quinones |
| 90 | KIN | Hallway by LR 25 S | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 91 | KIN | Hallway by LR 25 N | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 92 | KIN | E Gym S Side | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 93 | KIN | E Gym N Side | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 94 | KIN | Hallway by Rm 98 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 95 | KIN | Dance Rm 107 (Life Fit) | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 96 | KIN | Hallway by Rm 121 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 97 | KIN | Womens LR S Hallway | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 98 | HHS1 | 2nd FL NW Exterior | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 99 | HHS2 | 2nd FL NE | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 100 | Dance | 1st FL E Hallway | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 101 | Dance | 2nd FL W | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 102 | Dance | 2nd FL in LR S200 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |

| | | | | | | |
|-----|-------|---------------------|-----------|---------------------|--|-----------------------------|
| 103 | Dance | 2nd FL SE | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 104 | Dance | 3rd FL W by Rm S302 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 105 | Dance | 3rd FL SE | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 106 | UMC | Hallway by A400 | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 107 | UMC | Hallway A Side | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 108 | UMC | Recital Hall Lobby | 1/4/2018 | Negative (< 15 ppb) | | Stericycle- Andres Quinones |
| 109 | MKnob | Lobby | 1/17/2018 | Negative (< 15 ppb) | | Michael Kitahara |
| 110 | TA | Room 23 | 1/17/2018 | Positive (>15 ppb) | | Michael Kitahara |
| 111 | TA | Room 36 | 1/17/2018 | Negative (< 15 ppb) | | Michael Kitahara |

